

SEE  
HARLOW



# CITY OF HUNTINGTON BEACH

2000 MAIN STREET

CALIFORNIA 92648

FIRE DEPARTMENT FIRE PREVENTION DIVISION

To: Scott Hess, Planning Manager  
From: Charles W. Burney, Fire Marshal/Division Chief *CWB*  
Date: November 19, 2003

**SUBJECT: PARKSIDE FUEL MODIFICATION PLAN**

---

The Huntington Beach Fire Department now has responsibility for the emergency response into the environmentally sensitive habitat, park and recreation areas adjacent to the Parkside residential development. This residential development is not considered to be within a Wildland Interface zone and does not require a fuel modification plan.

However, planning of the habitat area should take into consideration a 100 feet low vegetation buffer along the common border with the homes. The existing plant material that is currently in this 100 feet zone should not present any problem for future development as it relates to the approved subdivision plans.

cc. Duane Olson, Fire Chief  
Matt McGrath, Supr. DevPetroChem  
Development file